


FRONT VIEW TYPE III-AF SERVICE EQUIPMENT ENCLOSURE (TYPICAL)

SERVICE EQUIPMENT ENCLOSURE

Standard Plan ES-20



NOTES (FOR SERVICE EQUIPMENT)

30 A, IP, Test switch

Photoelectric unit

15 A, 120 V, IP, CB

15 A, 120 V, IP, CB

15 A, IP, Test switch

Ground lug

Ground rod

(8)

(9)

(II)

(12)

I. Voltage ratings of service equipment shall conform to the service voltages indicated on the plans.

Sign Illumination

Flashing Beacon

Sign Illumination Test Switch

Sian Illumination Control

- 2. Unless otherwise indicated on the plans, all service equipment items shall be provided for each service equipment enclosure as shown.
- 3. Connect to remote test switch mounted on lighting standards, sign post or structure when required.
- 4. Item No. (1) and (6) shall be insulated from the cabinet.
- 5. Meter sockets shall be 5 clip type.

STATE OF CALIFORNIA DEPARTMENT OF TRANSPORTATION

Lighting Control

Light Test Switch

Lighting

HISNS

SIGNAL, LIGHTING AND **ELECTRICAL SYSTEMS** SERVICE EQUIPMENT AND TYPICAL WIRING DIAGRAM TYPE III-A SERIES

Photoelectric unit

15 A, 120 V, IP, CB

20 A, I20 V, IP, CB

29 23

15 A, IP, Test switch

60 A. 2PNO Contactor

30 A. 2PNO Contactor

These "Standard Plans for Construction of Local Streets and Roads" contain units in two systems of measurement: International System of Units (SI or "metric") and United States
Standard Measures shown in the parentheses (). The measurements expressed in the two systems are not necessarily equal or interchangeable. See the "Foreword" at the beginning of this publication.

NO SCALE